

AirCheckup Bioaerosol Report

Sampler ID: 132158

Test Start: 04.08.2022 14:25:00

Report Date: 08.09.2022

Test End: 05.08.2022 14:25:00

Exposure: 1 days, 0 hours, 0 minutes

Scope:


Bioaerosols are airborne compounds or microfragments from plant or animal matter or from microorganisms but also comprise whole microorganisms that are either dead or alive. Exposure to these agents may cause infectious diseases, allergic diseases, acute toxic effects, respiratory diseases, neurological effects, and possibly cancer.

Test Result:



Caution. Your test result is higher than normal.

The graph shows your test result as a percentage of AVG which is the average of all test results from our data base. We recommend that your test result be close to or lower than 100% (AVG). See also suggestions on improving indoor air quality below.



Suggestions to reduce total airborne particles:

- Keep relative air humidity at about 50%
- Increase fresh air by increasing ventilation.
- Use vacuum cleaners with HEPA micro filters which can filter particles to 0.3 microns.
- Prevent contamination from entering by placing footwear cleaning mats outside entrances.
- Replace air filters in the heating, ventilation and air conditioning (HVAC) system.
- Store chemicals in well ventilated areas.
- Retest air from time to time.